



Ref. Certif. No.

DE 2-026560

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Recessed luminaries

Name and address of the applicant

HEXALIGHT AYDINLATMA PROJE TASARIM MÜHENDISLIK SAN. VE
TIC. LTD. STİ.
İKİTELLİ OSB MAH. ESKOOP SAN. SİT.
A3-2 BLOK NO:133/134, BASAKSEHIR, 34490 ISTANBUL, Türkiye

Name and address of the manufacturer

HEXALIGHT AYDINLATMA PROJE TASARIM MÜHENDISLIK SAN. VE
TIC. LTD. STİ.
İKİTELLİ OSB MAH. ESKOOP SAN. SİT.
A3-2 BLOK NO:133/134, BASAKSEHIR, 34490 ISTANBUL, Türkiye

Name and address of the factory

HEXALIGHT AYDINLATMA PROJE TASARIM MÜHENDISLIK SAN. VE
TIC. LTD. STİ.
İKİTELLİ OSB MAH. ESKOOP SAN. SİT.
A3-2 BLOK NO:133/134, BASAKSEHIR, 34490 ISTANBUL, Türkiye

Ratings and principal characteristics

AC 220-240V; 50-60Hz; Class II;
Front part: IP40 / Recessed part: IP20;
Refer to test report for technical details.

Trademark (if any)

HEXALIGHT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SKY-x-y-z-OP; CRT-x-y-z-OP; VRO-x-y-z-OP;
(x, y, z are variables)
VNT-36-40-REF; RIO-10-40-REF; RNG-28-40-REF;
DRO-28-40-REF; RNA-28-30-REF; DIA-28-30-REF
Refer to test report for model differences.Additional information (if necessary may
also be reported on page 2)A sample of the product was tested and
found to be in conformity withIEC 60598-2-2:2011
IEC 60598-1:2014 + A1
See Test Report for National DifferencesAs shown in the Test Report Ref. No. which
forms part of this Certificate

27142945 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland LGA Products GmbH
Tillystraße 2 · 90431 Nürnberg, Germany
Phone + 49 221 806-1371
Fax + 49 221 806-3935
Mail: cert-validity@de.tuv.com
Web: www.tuv.com

Date: 26.12.2019

Signature:

Ece Yücel EL Alawi